

## **Hutt City Council**

Specified Systems		
Building consent number:		
Site address:		
Building owner(s)	Name(s): Contact details:	
Location of building or building work within site/block number/building:		
Description:	<ul> <li>This inspection is to check:</li> <li>The specified systems affected by the granted building consent</li> <li>The interfacing between specified systems</li> <li>The performance standards for the specified systems affected by the building consent</li> <li>The inspection, maintenance and reporting procedures for the specified systems affected by the building consent</li> </ul>	
When to book this inspection	Book this inspection when building work on the specified systems that are affected by the granted building consent has been completed.	
Building Inspector:	Name:	Warrant number:
Inspection date and time:	Click or tap to enter a date.	Time:
Inspection attendees:		
Specified Systems		
Items to be checked	Help Text	
	<ol> <li>Is the specified system new, altered, added or removed? Please state.</li> <li>Has the new specified system been installed as per the building consent?</li> <li>Has the specified system been added and installed as per the building consent?</li> </ol>	



- 4. Has the existing specified system been altered as per the building consent?
- 5. Has the existing specified system been removed as per the building consent?
- 6. Are the functional relationships between specified systems as per the building consent?
- 7. Are the performance standards for the specified system as per the building consent? If there are changes to the performance standards, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 8. Are the inspections procedures for the specified system as per the building consent? If there are changes to the inspection procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 9. Are the inspections frequencies for the specified system as per the building consent?

10. Are the inspection personnel for the specified system as per the building consent?

If there are changes to the inspection personnel, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.



11. Are the maintenance procedures for the specified system as per the building consent? If there are changes to the maintenance procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

12. Are reporting procedures for the specified system as per the building consent? If there are changes to the reporting procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

- 1. Is the specified system new, altered, added or removed? Please state.
- 2. Has the new specified system been installed as per the building consent?
- 3. Has the specified system been added and installed as per the building consent?
- 4. Has the existing specified system been altered as per the building consent?
- 5. Has the existing specified system been removed as per the building consent?
- 6. Are the functional relationships between specified systems as per the building consent?
- 7. Are the performance standards for the specified system as per the building consent?

  If there are changes to the performance standards, has either an amendment to the building consent



- 8. Are the inspections procedures for the specified system as per the building consent? If there are changes to the inspection procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 9. Are the inspections frequencies for the specified system as per the building consent?

If there are changes to the inspection frequencies, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

- 10. Are the inspection personnel for the specified system as per the building consent?

  If there are changes to the inspection personnel, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 11. Are the maintenance procedures for the specified system as per the building consent? If there are changes to the maintenance procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 12. Are reporting procedures for the specified system as per the building consent?

  If there are changes to the reporting procedures, has either an amendment to the building consent



TE AWA KAIR
or minor variation to the building consent been
granted for the changes. If no, fail the inspection.
<ol> <li>Is the specified system new, altered, added or removed? Please state.</li> </ol>
2. Has the new specified system been installed as per the building consent?
3. Has the specified system been added and installed as per the building consent?
4. Has the existing specified system been altered as per the building consent?
5. Has the existing specified system been removed as per the building consent?
6. Are the functional relationships between specified systems as per the building consent?
7. Are the performance standards for the specified system as per the building consent?
If there are changes to the performance standards,
has either an amendment to the building consent
or minor variation to the building consent been
granted for the changes. If no, fail the inspection.
8. Are the inspections procedures for the specified system as per the building consent?
If there are changes to the inspection procedures,
has either an amendment to the building consent
or minor variation to the building consent been granted for the changes. If no, fail the inspection.
9. Are the inspections frequencies for the specified system as per the building consent?



10. Are the inspection personnel for the specified system as per the building consent?

If there are changes to the inspection personnel, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

11. Are the maintenance procedures for the specified system as per the building consent? If there are changes to the maintenance procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

12. Are reporting procedures for the specified system as per the building consent?

If there are changes to the reporting procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

- 1. Is the specified system new, altered, added or removed? Please state.
- 2. Has the new specified system been installed as per the building consent?
- 3. Has the specified system been added and installed as per the building consent?
- 4. Has the existing specified system been altered as per the building consent?



- 5. Has the existing specified system been removed as per the building consent?
- 6. Are the functional relationships between specified systems as per the building consent?
- 7. Are the performance standards for the specified system as per the building consent? If there are changes to the performance standards, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 8. Are the inspections procedures for the specified system as per the building consent? If there are changes to the inspection procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 9. Are the inspections frequencies for the specified system as per the building consent?

10. Are the inspection personnel for the specified system as per the building consent?

If there are changes to the inspection personnel, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

11. Are the maintenance procedures for the specified system as per the building consent?



12. Are reporting procedures for the specified system as per the building consent?

If there are changes to the reporting procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

- 1. Is the specified system new, altered, added or removed? Please state.
- 2. Has the new specified system been installed as per the building consent?
- 3. Has the specified system been added and installed as per the building consent?
- 4. Has the existing specified system been altered as per the building consent?
- 5. Has the existing specified system been removed as per the building consent?
- 6. Are the functional relationships between specified systems as per the building consent?
- 7. Are the performance standards for the specified system as per the building consent? If there are changes to the performance standards, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.



- 8. Are the inspections procedures for the specified system as per the building consent?

  If there are changes to the inspection procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 9. Are the inspections frequencies for the specified system as per the building consent?

- 10. Are the inspection personnel for the specified system as per the building consent?

  If there are changes to the inspection personnel, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 11. Are the maintenance procedures for the specified system as per the building consent? If there are changes to the maintenance procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 12. Are reporting procedures for the specified system as per the building consent?

  If there are changes to the reporting procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.



- Is the specified system new, altered, added or removed? Please state.
- 2. Has the new specified system been installed as per the building consent?
- 3. Has the specified system been added and installed as per the building consent?
- 4. Has the existing specified system been altered as per the building consent?
- 5. Has the existing specified system been removed as per the building consent?
- 6. Are the functional relationships between specified systems as per the building consent?
- 7. Are the performance standards for the specified system as per the building consent?

  If there are changes to the performance standards, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 8. Are the inspections procedures for the specified system as per the building consent? If there are changes to the inspection procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 9. Are the inspections frequencies for the specified system as per the building consent?

If there are changes to the inspection frequencies, has either an amendment to the building consent



10. Are the inspection personnel for the specified system as per the building consent?

If there are changes to the inspection personnel, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

11. Are the maintenance procedures for the specified system as per the building consent? If there are changes to the maintenance procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

12. Are reporting procedures for the specified system as per the building consent?

If there are changes to the reporting procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

- 1. Is the specified system new, altered, added or removed? Please state.
- 2. Has the new specified system been installed as per the building consent?
- 3. Has the specified system been added and installed as per the building consent?
- 4. Has the existing specified system been altered as per the building consent?
- 5. Has the existing specified system been removed as per the building consent?



- 6. Are the functional relationships between specified systems as per the building consent?
- 7. Are the performance standards for the specified system as per the building consent?

  If there are changes to the performance standards, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 8. Are the inspections procedures for the specified system as per the building consent? If there are changes to the inspection procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 9. Are the inspections frequencies for the specified system as per the building consent?

- 10. Are the inspection personnel for the specified system as per the building consent?

  If there are changes to the inspection personnel, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 11. Are the maintenance procedures for the specified system as per the building consent? If there are changes to the maintenance procedures, has either an amendment to the building consent or minor variation to the building



consent been granted for the changes. If no, fail the inspection.

12. Are reporting procedures for the specified system as per the building consent?

If there are changes to the reporting procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

- 1. Is the specified system new, altered, added or removed? Please state.
- 2. Has the new specified system been installed as per the building consent?
- 3. Has the specified system been added and installed as per the building consent?
- 4. Has the existing specified system been altered as per the building consent?
- 5. Has the existing specified system been removed as per the building consent?
- 6. Are the functional relationships between specified systems as per the building consent?
- 7. Are the performance standards for the specified system as per the building consent? If there are changes to the performance standards, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 8. Are the inspections procedures for the specified system as per the building consent? If there are changes to the inspection procedures, has either an amendment to the building consent



9. Are the inspections frequencies for the specified system as per the building consent?

If there are changes to the inspection frequencies, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

10. Are the inspection personnel for the specified system as per the building consent?

If there are changes to the inspection personnel, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

11. Are the maintenance procedures for the specified system as per the building consent? If there are changes to the maintenance procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

12. Are reporting procedures for the specified system as per the building consent?

If there are changes to the reporting procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

- 1. Is the specified system new, altered, added or removed? Please state.
- 2. Has the new specified system been installed as per the building consent?



- 3. Has the specified system been added and installed as per the building consent?
- 4. Has the existing specified system been altered as per the building consent?
- 5. Has the existing specified system been removed as per the building consent?
- 6. Are the functional relationships between specified systems as per the building consent?
- 7. Are the performance standards for the specified system as per the building consent? If there are changes to the performance standards, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 8. Are the inspections procedures for the specified system as per the building consent? If there are changes to the inspection procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 9. Are the inspections frequencies for the specified system as per the building consent?

10. Are the inspection personnel for the specified system as per the building consent?

If there are changes to the inspection personnel, has either an amendment to the building consent



11. Are the maintenance procedures for the specified system as per the building consent? If there are changes to the maintenance procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

12. Are reporting procedures for the specified system as per the building consent?

If there are changes to the reporting procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

- 1. Is the specified system new, altered, added or removed? Please state.
- 2. Has the new specified system been installed as per the building consent?
- 3. Has the specified system been added and installed as per the building consent?
- 4. Has the existing specified system been altered as per the building consent?
- 5. Has the existing specified system been removed as per the building consent?
- 6. Are the functional relationships between specified systems as per the building consent?
- 7. Are the performance standards for the specified system as per the building consent?



- 8. Are the inspections procedures for the specified system as per the building consent? If there are changes to the inspection procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 9. Are the inspections frequencies for the specified system as per the building consent?

If there are changes to the inspection frequencies, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.

- 10. Are the inspection personnel for the specified system as per the building consent?

  If there are changes to the inspection personnel, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 11. Are the maintenance procedures for the specified system as per the building consent? If there are changes to the maintenance procedures, has either an amendment to the building consent or minor variation to the building consent been granted for the changes. If no, fail the inspection.
- 12. Are reporting procedures for the specified system as per the building consent?

